

OWNERSHIP	CITY OF COLUMBUS	STA. 70+00	STA. 75+10
JURISDICTION / PARCEL ID	CITY OF COLUMBUS / FRANKLIN COUNTY		
TEST PRESSURE / DESIGN INFO	1080 PSIG MIN / 1280 PSIG MAX / CLASS IV / 720 PSIG		
CONSTRUCTION METHOD	OPEN CUT		
PIPE			
FITTINGS			

HORIZONTAL STATIONING

(SCALE: 1" = 40')

PROPOSED PLAN

(SCALE HORIZ: 1" = 40' / SCALE VERT: 1" = 20')

PROPOSED PROFILE

NOTES:

1. CONTRACTOR SHALL VERIFY ALL UTILITY CROSSINGS

2. SERVICE LINE CROSSINGS SHOWN IN SURVEY ARE NOT STATIONED OR SHOWN IN PROFILE FOR CLARITY

3. THE PIPELINE HAS GENERALLY BEEN DESIGNED WITH A COVER OF 6'-0" TO ACCOUNT FOR THE DEPTH OF UNKNOWN SERVICE LINES. MINIMUM ALLOWABLE
4. DEPTH OF COVER IS 4'-0"

5. VERTICAL BENDS CALLED OUT IN PROFILE ARE FOR REFERENCE. CONTRACTOR TO MAKE USE OF ROPING AND FIELD BENDS WHERE POSSIBLE. REFER TO GS 3010.030 FOR FURTHER DETAILS

6. CORROSION PROTECTION IS DESIGNED BY NISOURCE AND IS NOT COVERED WITHIN THE ENGINEER'S STAMP
6. AERIAL IMAGERY IS FOR REFERENCE ONLY

7. FITTING EXTENTS SHOWN IN THE PROFILE ARE FOR REFERENCE ONLY. REFER TO STATIONING BAND FOR LOCATIONS OF ANTICIPATED FITTINGS. A 3X DIAMETER OF STRAIGHT PIPE IS REQUIRED BETWEEN ALL FITTINGS. REFER TO GS 2110.020 FOR FURTHER DETAILS

NiSource

Ohio Utilities Protection Service
Call 811 before you dig

CAMPOS
EPC

401 N Front St, Suite 380, Columbus, OH 43215
(380) 799-8503

PROPOSED

REVISIONS

B	06/18/25	REVISED FOR FUTURE TIE-IN
A	12/23/24	ISSUED FOR PERMIT
REV. #	DATE	DESCRIPTION
INTERNAL ENG.	AD	12/23/24 614-981-0661
DESIGNED BY	JMJ	12/23/24 855-266-7671
CHECKED BY	RBW	12/23/24 855-266-7671
AS-BUILT BY	TBD	TBD TBD
	NAME	DATE PHONE #

SITE NAME:
INST# 23-0083895-00
ABAN# 23-0083897-00
PROJECT ID# 21-78793
AGLER ROAD NCHP PIPELINE PROJECT
COLUMBUS/GAHANNA, FRANKLIN COUNTY, OH

DRAWING TITLE:

STA. 70+00 TO STA. 75+10

DRAWING NO:

L-2009